

February 4, 2010

MURPHY SEPTIC SERVICE  
**TREVOR MURPHY**  
1840 CYPRESS RD  
DEPERE WI 54115

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: MURPHY SEPTIC SERVICE  
Product Name: SEPTIC, HOLDING OR PUMP  
Model Number(s): 2054 GAL. **(2500 GAL. HOLDING)**  
(49.5 IN. L.L., 42.73 GAL./IN.; 48 IN. MAX. DEPTH OF BURY, 1013 G.P.D. WHEN USED  
AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER; TANK DIMENSIONS= 138 IN. L X 68.5 IN. W X 58.8 IN. H)  
Product File No: 20090389

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of JANUARY 2015.

This approval is contingent upon compliance with the following stipulation(s):

- The products produced by this manufacturer are approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or manhole in lieu of observation/vent opening.
  - Optional inlet opening through tank cover using cast iron 90 degree ell with pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover for holding or pump tank use.
  - Bottom openings for holding tank and for pump tank or compartment.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- AS OF MARCH 1, 2009, SECTION COMM 84.10 WAS MODIFIED AND THE REVIEW OF EXTERIOR GREASE INTERCEPTORS AS A PLUMBING PRODUCT IS NO LONGER REQUIRED. REVIEW WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.
- **Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ inches screen.**

This approval supersedes the approval issued on 8/30/2005 under product file number 20050676.

MURPHY SEPTIC SERVICE  
Page 2  
February 4, 2010  
PRODUCT FILE NO. 20090389

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050676.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov